

SPRING PROTECTION PROGRAM

EVALUATION REPORT

SPRINGS OVER ONE YEAR AFTER PROTECTION.

AIM OF EVALUTION.

1. Close the spring protection contract as agreed by the contractor.
2. Asses the usage by the community.
3. Asses the maintenance standard by the Committee.
4. Develop issue to discuss with various committees on the way forward.

No	SPRING	YEAR	WATER FLOW	USAGE	ISSUES IDENTIFIED	WHO TO ADDRESS ISSUES IDENTIFIED	PLAN OF ACTION	TIME FRAME
1	Mwichope community spring	Feb/March 2018	Good	The local villages and beyond -Good flow. -Good usage by the community	1. Water drainage functioning well	Encourage the community to keep up	Follow up in future	
2	Nakhakosia community spring	Feb/March 2018	Good	The locals	-Because of rainfall ,water increased and it's too much for one pipe	The Contractor	Follow up in immediately and ensure the contractor adds an overflow pipe.	Immediate action taken and an over flow pipe put in place

After visiting the two springs that were protected more than one year ago.

We would wish to report that the springs are all in good shape as can be in the pictures

The water flow is good and the community is using them well.

Spring Nakhakosia has a lot of water which was becoming too much for one pipe and therefore the contractor was requested to add an overflow pipe which was done immediately.

The communities visited are very grateful for the support.

Many people were working on the farms, so not many captured fetching water!

RECOMMEDATIONS.

It's worth supporting the community to be able to access clean and safe water for their use.

We encourage the clubs sponsoring to continue with the good work

Please see the pictures of each spring in the attachment.